

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1




HA-01 Non-asbestos containing yellow carpet mastic




HA-02 Non-asbestos containing 4" black cove molding and associated mastic

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-03 Non-asbestos containing white smooth wall plaster




HA-04 Non-asbestos containing white smooth ceiling plaster

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-05 Non-asbestos containing interior gray window caulk



HA-06 Non-asbestos containing white 2' x 2' lay-in ceiling tile with texture and holes

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-07 Non-asbestos containing domestic water pipe straight insulation



HA-08 Non-asbestos containing drywall

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-09 Non-asbestos containing drywall joint compound



HA-10 Assumed asbestos-containing ceramic floor tile bedding compound and grout

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-11 Assumed asbestos-containing ceramic wall tile bedding compound and grout




HA-12 Non-asbestos containing wallpaper and paste

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-13 Non-asbestos containing gray sink undercoating



HA-14 Non-asbestos containing white 12" x 12" floor tile

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-15 Non-asbestos containing mastic associated with 12" x 12" floor tile



HA-16 Assumed asbestos-containing black roof shingles and tar paper



Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-17 Non-asbestos containing exterior green window caulk



HA-18 Non-asbestos containing exterior white door frame caulk

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-19 Non-asbestos containing exterior brown building caulk



HA-20 Non-asbestos containing exterior white rubber door frame caulk

Albert J. Cook Hall  
458 West Circle Drive  
East Lansing, Michigan  
Fibertec Project #40414-1



HA-21 Non-asbestos containing exterior white railing caulk



HA-22 Non-asbestos containing exterior black window caulk