

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log




MSU Alumni Chapel (#30)

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log




HA #1 –Asbestos containing 9”x 9” Dark brown floor tile with white and cream streaks (mastic negative)

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #2 – Non asbestos containing 4” Brown cove molding and associated mastic

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log




HA #3 – Asbestos containing 9”x 9” Light brown floor tile with white and black streaks (mastic negative)

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #4 – Non asbestos containing 4” Green cove molding and associated mastic

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #5 – Assumed asbestos containing Multi shade and size brown ceramic tile and bedding compound

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #6 – Assumed asbestos containing Tan ceramic wall tile and associated bedding compound

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log




HA #7 – Assumed asbestos containing Orange ceramic tile and associated bedding compound

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #8 – Asbestos Containing Medium textured plaster

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log




HA #9 – Non asbestos containing light texture skim coat plaster

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #10 –Asbestos containing Black sink undercoating

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #11 –Asbestos containing Straight pipe insulation

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #12 – Asbestos containing pipe joint and hanger insulation

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #13 – Non asbestos containing Smooth white plaster

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #14 – Asbestos containing Mag tank insulation

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #15 –asbestos containing black gluepods on Green soundproofing
(Green soundproofing NON-ACM)

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #16 – Assumed asbestos containing Fire door and frames

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #17 – Assumed asbestos containing 2”x 2” Brown ceramic tile and bedding compound

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #18 – Assumed asbestos containing Green marble tile and bedding compound

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #19 – Assumed asbestos containing black vinyl sheet flooring and associated mastic

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #20 – Assumed asbestos containing Black vinyl pedal tread and associated mastic

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #21 – Assumed asbestos containing Roofing materials and products

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #22 – Assumed asbestos containing Light gray masonry caulk

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #23 – Asbestos containing White bell tower building caulk

Michigan State University
Alumni Memorial Chapel - Asbestos Inspection Photo Log



HA #24 – Assumed asbestos containing White window glazing

HA #25 – Assume asbestos containing White window caulk