


I.M. Circle Photo Log



Main entrance to I.M. Sports Circle

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #1 – Non asbestos-containing plaster

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #2 – Non asbestos-containing 12" x 12" white ceiling tile
with random holes and associated glue pods

I.M. Circle Photo Log



HA #3 – Asbestos-containing 9" x 9" brown floor tile
with cream and rust streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #4 – Non asbestos-containing 12" x 12" white slotted ceiling tile
with associated glue pods

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #5 – Asbestos-containing reddish linoleum flooring and stair tread with cream streaks and associated non asbestos-containing mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #6 – Asbestos-containing brown linoleum flooring and stair tread with cream and rust streaks and associated non asbestos-containing mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #7 – Non asbestos-containing 4" brown cove molding
and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA # 8 – Non asbestos-containing 4" black cove molding
and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #9 – Non asbestos-containing 2' x 2' white lay-in ceiling tile
with pin holes and fissures

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #10 – Non asbestos-containing 2' x 4' white lay-in ceiling tile
with pin holes

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #11 – Asbestos-containing light heat shield

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #12 – Assumed asbestos-containing chalkboards
and associated glue pods

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #13 – Asbestos-containing steam/condensate supply and return pipe straight insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #14 – Asbestos-containing steam/condensate supply and return pipe joint and hanger insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #15 – Non asbestos-containing ventilation duct expansion cloth

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #16 – Non asbestos-containing glue pods from
12" x 12" fiberglass ceiling tile

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #17 – Non asbestos-containing 12" x 12" white floor tile
with green marble pattern and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #18 – Non asbestos-containing 2' x 2' white drop-in ceiling tile
with pin holes and fissures

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #19 – Non asbestos-containing black sink undercoating

I.M. Circle Photo Log



HA #20 – Non asbestos-containing drywall

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log




HA #21 – Non asbestos-containing drywall joint compound

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #22 – Asbestos-containing domestic water supply
pipe joint and hanger insulation


I.M. Circle Photo Log



HA #23 – Asbestos-containing 9" x 9" cream floor tile
with pink and tan streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #24 – Non asbestos-containing 12" x 12" white ceiling tile with pin holes and fissures and associated glue pods

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #25 – Asbestos-containing 9" x 9" light tan floor tile with pink, cream and brown streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #26 – Non asbestos-containing white sink undercoating

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #27 – Non asbestos-containing 12" x 12" black floor tile
and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #28 – Asbestos-containing domestic water supply
pipe straight insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #29 – Asbestos-containing 9" x 9" beige floor tile with dark brown and tan marble pattern and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #30 – Asbestos-containing 9" x 9" gray floor tile with cream specks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #31 – Non asbestos-containing 6" brown cove molding
and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #32 – Assumed asbestos-containing fire door and frame

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #34 – Asbestos-containing drain pipe joint and hanger insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #35 – Asbestos-containing 9" x 9" light brown floor tile with cream and rust streaks and associated non asbestos-containing mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log




HA #36 – Assumed asbestos-containing roofing materials and products

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #36 – Assumed asbestos-containing roofing materials and products

I.M. Circle Photo Log



HA #37 – Non asbestos-containing 2' x 2' white lay-in ceiling tile
with pin holes

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #39 – Assumed asbestos-containing black chemistry lab countertop

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #40 – Asbestos-containing expansion tank insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #41 – Non asbestos-containing cream vinyl flooring
and associated backing

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #42 – Non asbestos-containing 4" gray cove molding
and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #43 – Assumed asbestos-containing transite wall panels

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #44 – Asbestos-containing 9" x 9" green floor tile with green and white marble pattern and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #45 – Asbestos-containing 9" x 9" white floor tile with green streaks and associated non asbestos-containing mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #46 – Non asbestos-containing red linoleum with rust streaks
and associated backing

For more information contact MSU Environmental Health and Safety – (517) 353-8956


I.M. Circle Photo Log



HA #47 – Non asbestos-containing 12" x 12" green floor tile with dark green and tan specks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #48 – Non asbestos-containing 12" x 12" white ceiling tile
with uniform holes and associated glue pods

For more information contact MSU Environmental Health and Safety – (517) 353-8956

I.M. Circle Photo Log



HA #49 – Assumed asbestos-containing building caulk compound

For more information contact MSU Environmental Health and Safety – (517) 353-8956