

Natural Resources Photo Log



Asbestos-containing domestic water pipe joint and
hanger insulation on fiberglass straight

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Asbestos-containing chilled water pipe joint/hanger insulation
on fiberglass straight

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Asbestos-containing wastewater pipe joint/hanger insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Asbestos-containing hot water holding tank insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Asbestos-containing drain line pipe joint/hanger insulation on fiberglass

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Assumed asbestos-containing fire door and frame

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 2' x 4' white lay-in ceiling tile with pin holes and fissures

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 4" black cove molding and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Asbestos-containing duct wrap insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Asbestos-containing 9" x 9" white floor tile
with gray streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing plaster


For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Assumed asbestos-containing fire door and frame

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Non asbestos-containing gray sink undercoating

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Asbestos-containing 9" x 9" gray floor tile
with white streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Non asbestos-containing white sink undercoating

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 12" x 12" white ceiling tile with pin holes and fissures and associated glue pods

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing drywall and drywall joint compound

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 12" x 12' tan floor tile
with multi-colored specks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 4" brown cove molding and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 12" x 12" tan and brown marble floor tile and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Asbestos-containing steam/condensate pipe straight insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 2' x 2' white drop-in ceiling tile with rough texture

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 4" mauve cove molding and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956



Asbestos-containing black sink undercoating

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 12" x 12" dark green
marble pattern floor tile and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 12" x 12" orange
marble pattern floor tile and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Non asbestos-containing 12" x 12" light green
marble pattern floor tile and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Assumed asbestos-containing gray exterior window and door frame caulk

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Natural Resources Photo Log



Assumed asbestos-containing gray exterior window and door frame caulk

For more information contact MSU Environmental Health and Safety – (517) 353-8956