

Akers Hall Photo Log



HA #2
Non asbestos-containing textured plaster

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #3
Asbestos-containing spray-on acoustical plaster

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #4
Non asbestos-containing white stipple plaster

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #5
Non asbestos-containing drywall

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #6
Non asbestos-containing drywall joint compound

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #7
Non asbestos-containing 2' x 2' white drop-in ceiling tile
with pin holes and fissures

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log




HA #8

Non asbestos-containing 2' x 2' white lay-in ceiling tile with pin holes

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #9
Non asbestos-containing 12" x 12" white splined ceiling tile
with pin holes and fissures

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #10

Non asbestos-containing 4" brown cove molding and associated mastic

HA #18

Asbestos-containing 9" x 9" dark tan floor tile
with cream and rust streaks and associated non asbestos-containing mastic

HA #19

Asbestos-containing 9" x 9" chocolate brown floor tile
with cream and rust streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #11

Non asbestos-containing 4" black cove molding and associated mastic

HA #23

Non asbestos-containing light green linoleum
with mosaic pattern and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #12

Non asbestos-containing 4" gray cove molding and associated mastic

HA #15

Non asbestos-containing 12" x 12" cream floor tile
with white and gray streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #13
Non asbestos-containing 12" x 12" tan floor tile with marbled pattern
and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #14

Non asbestos-containing 12" x 12" tan floor tile with cream and rust streaks
and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #15
Non asbestos-containing 12" x 12" cream floor tile
with white and gray streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #16
Non asbestos-containing 12" x 12" white floor tile
with tan marble pattern and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #17
Asbestos-containing 12" x 12" light cream floor tile
with tan and cream streaks and associated non asbestos-containing mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #20
Non asbestos-containing gray flooring
with black and white specks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #21
Non asbestos-containing green linoleum
with tan and black specks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #22

Non asbestos-containing tan linoleum with cream swirls and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #24

Non asbestos-containing dark green linoleum
with black and cream specks and associated mastic

HA #49

Non asbestos-containing forest green linoleum
with black, cream and light green specks and associated mastic.

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #25
Non asbestos-containing chocolate vinyl stair tread
with black, cream and pink streaks and associated asbestos-containing mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #26
Non asbestos-containing chocolate vinyl stair tread
with cream streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #28

Non asbestos-containing steam/condensate supply and return pipe joint insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #28

Non asbestos-containing steam/condensate supply and return pipe joint insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #30
Asbestos-containing domestic water supply and return
pipe joint and hanger insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #33

Non asbestos-containing canvas wrap on fiberglass pipe straight insulation

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #34
Asbestos-containing white ventilation duct expansion cloth

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #34
Asbestos-containing white ventilation duct expansion cloth

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #39
Non asbestos-containing 9” x 9” cream floor tile
with rust streaks and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #40
Asbestos-containing spray-on fireproofing

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #41
Non asbestos-containing black ventilation duct expansion cloth

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #42

Non-asbestos containing 4" tan cove molding and associated mastic

HA #1

Asbestos-containing plaster (smooth)

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #43
Non asbestos-containing light tan linoleum
with bubble pattern and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #44
Non asbestos-containing black sink undercoating

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #45

Non asbestos-containing 2' x 2' white lay-in ceiling tile with smooth texture

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #46
Non asbestos-containing 12" x 12" brown floor tile
with marble pattern and associated mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #47
Non asbestos-containing 2' x 2' white lay-in ceiling tile
with pin holes and fissures

For more information contact MSU Environmental Health and Safety – (517) 353-8956



HA #48
Asbestos-containing silver expansion tanks

For more information contact MSU Environmental Health and Safety – (517) 353-8956

Akers Hall Photo Log



HA #50
Non asbestos-containing wood grain vinyl flooring
and associated asbestos-containing mastic

For more information contact MSU Environmental Health and Safety – (517) 353-8956