

Dairy Cattle Teaching and Research Main Barn Cost Estimate

COST ESTIMATE

A cost estimate to remove the identified ACM is provided in the following table, T-1:

**TABLE T-1
DAIRY CATTLE TEACHING AND RESEARCH CENTER**

RECOMMENDED ACTION	UNITS	UNIT COST	ESTIMATED COST*
Removal of steam/condensate supply and return pipe joint and hanger insulation	44 ct.	\$15.00/joint	\$660.00
Removal of domestic water supply pipe joint and hanger insulation	140 ct.	\$15.00/joint	\$2,100.00
Removal of drain line pipe joint and hanger insulation	15 ct.	\$15.00/joint	\$225.00
Removal of window and door frame caulk compound	830 l.f.	\$4.00/l.f.	\$3,320.00
Removal of transite wall and ceiling panels (majority beneath wall and ceiling covering)	19,200 s.f.	\$10.00/s.f.	\$192,000.00
Removal of transite roof vent covers	18 s.f.	\$6.00/s.f.	\$108.00
Removal of drywall joint compound and associated drywall	1,000 s.f. (2,000 s.f. of drywall)	\$6.00/s.f.	\$6,000.00
Removal of chalkboards and associated glue pods	3 ct.	\$125.00/unit	\$375.00
Removal of light heat shield	1 ct.	\$50.00/unit	\$50.00

GRAND ESTIMATED TOTAL

\$204,838.00

* The cost estimates are based on current industry prices. Industry prices may change at any time. It is assumed that the work is performed by licensed, competent organizations. Estimates include all costs of abatement projects except replacement. Estimated cost is based on project size, difficulty, access, and all work being done at one time, etc. Some savings may be possible by combining projects.